



North Lincoln Fire & Rescue District #1

Office of the Fire Marshal

PO Box 200, Lincoln City, OR 97367

541-996-2233

541-996-5344 (Fax)

Website: www.nlfr.org

WHEN IS A PERMIT FROM THE FIRE MARSHAL REQUIRED FOR A TENT, CANOPY, or AIR SUPPORTED STRUCTURE? OFC 105.7.16

Definitions:

TENT: a structure, enclosure or shelter, with or without sidewalls or drops, constructed of fabric or pliable material supported by any manner except by air or the contents that it protects.

CANOPY: a TENT completely open on ALL SIDES

AIR SUPPORTED STRUCTURE: A structure where the shape of the structure is attained by air pressure (examples: Air supported domes; Bounce Houses)

Any tent larger than 400 square feet



PERMIT REQUIRED

Any canopy over 700 square feet



PERMIT REQUIRED

*North Lincoln Fire & Rescue District #1
is committed to providing quality emergency services
through the efforts of dedicated personnel.*

Does the cumulative size of canopies grouped together exceed 700 square feet?



PERMIT REQUIRED

Because it is closed on one side, this is a TENT, NOT a canopy:





If over 400 square foot,
PERMIT REQUIRED



Bounce House over 400 square feet? **PERMIT REQUIRED**

EXAMPLES:

Let us use as an example several 15x15 square foot canopies
(each canopy is 225 square feet):



This flyer was put together only to provide general information on when a permit is required based on the size of the tent, canopy, or grouping.

If it is determined that a permit is required,
all other Oregon Fire Code requirements apply.

Tents or membrane structures shall not be located within 20 feet of lot lines, buildings, other tents or membrane structures, parked vehicles or internal combustion engines.

For further information, contact the North Lincoln Fire & Rescue District #1
Fire Marshal's Office at 541-996-2233